WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52928
Permit No.
Basin 163

NOTICE OF INTENT NO. 15924

1. OWNER Ed PARSONS
MAILING ADDRESS 2661 PRINCE AVE SANDY VALLEY
ADDRESS AT WELL LOCATION 2661 PRINCE AVE SANDY VALLEY NV

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 25 N/S R. 57 E CLARK County
PERMIT NO. ____ Issued by Water Resources | 590 390 093 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brn Clay		3	25	22
White Clay		25	60	35
Sandstone	X	60	75	15
Brn Clay + gravel		75	130	55
Volcanic Boulder		130	135	5
Brn Claystone	X	135	160	

JUL 17 1996

Date started 7/9/96, 19
Date completed 7/16/96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air test		
450 CFM @ 250 PSI		
160'		
60		
Developed For 3 hrs		

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188		

Perforations:
Type perforation Torch
Size perforation 1/4 X 10
From 100 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mitchell Ent Contractor
Address 4250 So Arville #262 Contractor
Los Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board 042266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Wean Mitchell
By driller performing actual drilling on site or contractor
Date 7/16/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627