WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52940
Permit No.
Basin 212

NOTICE OF INTENT NO. 17540

1. OWNER HARRAH'S
MAILING ADDRESS 3473 So. LAS VEGAS Blvd LAS VEGAS NV
ADDRESS AT WELL LOCATION 3473 S. LAS VEGAS BLVD, LAS VEGAS, NV

2. LOCATION SW ¼ SW ¼ Sec. 16 T 21 N/S R 61 E CLARK County
PERMIT NO. MO-2703 (Issued by Water Resources) | 162-16-005,006 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-1
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	5	5
SAND		5	8	3
CALICHE		8	13	5
SAND		13	15	2
CALICHE		15	23	8
SILTY CLAY		23	39	16
CLAYEY GRAVEL		39	40	1
SILTY CLAY		40	41	1
CLAYEY GRAVEL		41	43	2
SILTY CLAY		43	47	4
CLAY		47	50	3

DCNR/DWR Received JUL 30 1996 LAS VEGAS OFFICE

Date started APRIL 1, 1996
Date completed APRIL 1, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 50 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	50

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 20 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-15'/15-18' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 18 feet to 50 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (Contractor)
Address 731 PILOT RD STE H (Contractor)
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-25-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627