WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52946
Permit No.
Basin 162

NOTICE OF INTENT NO. 14931

1. OWNER WILD WEST HOMES
MAILING ADDRESS 1301 W DONNER
PAHRUMP, NV 89041

ADDRESS AT WELL LOCATION
1301 WEST DONNER STREET

2. LOCATION SE 1/4 NE 1/4 Sec. 17 T 20S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 36-303-08 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CALICHIA		0	25	25
DARK GREY CALICHIA		25	36	11
GREY CLAY		36	49	13
BEIGE CLAY	X	49	71	22
LIGHT BROWN CLAY	X	71	92	21
LIGHT BROWN CLAY	X	92	108	16
BEIGE CLAY	X	108	121	13
LIGHT BEIGE CLAY	X	121	140	19

Date started 7/18/96, 19__
Date completed 7/19/96, 19__

DCNR/DWR RECEIVED AUG 1 1996 LAS VEGAS OFFICE

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	N/A	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12" Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation TORCH
Size perforation .25 X 6
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 90 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address HC 78 BOX 80036 (Contractor)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, ~~the on-site~~ driller 1916
Signed Barry Strickland (By driller performing actual drilling on-site or contractor)
Date July 26 1996