LOWER

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 53092
Permit No.
Basin 105

NOTICE OF INTENT NO. 32932

1. OWNER FIVE CREEK LLC
MAILING ADDRESS Box 2410
MINDEN, NV 89423

ADDRESS AT WELL LOCATION NONE

2. LOCATION ~~SE~~ NE 1/4 ~~NW~~ SE 1/4 Sec. ~~15~~ 16 T. 12 N/S R. 19 E. DOUGLAS County

PERMIT NO. W 458 61928 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HILLSIDE AL		0	10	10
DG W LARGE BLDRS	X	10	140	130
FINER GRAINED, SOFTER DG	X	140	200	60
SOFT LT BROWN CLAY		190	200	10
MED SOFT DG	X	200	340	140
DG W THIN BROWN CLAY SEAMS, V SOFT	X	340	700	360

* PLUGGED HOLE W NEAT CEMENT FROM 700' UP TO 445'

38.899916°N
119.842952°W
NAD 27
NOI #63756
Plugged this well

Date started 4/30, 1996
Date completed 5/9, 1996

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200	?	4

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 445 Feet *

HOLE DIAMETER (BIT SIZE)

	From	To
15 Inches	0 Feet	55 Feet
13 Inches	~~55~~ Feet	~~500~~ Feet
Inches	5 Feet	445 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		1/4	+2	445

Perforations:
Type perforation SAWCUT + SCREEN
Size perforation 3X 3/32 .080
From 55 feet to 95 feet P
From 95 feet to 115 feet S
From 155 feet to 255 feet P
From 335 feet to 355 feet S
From ~~405~~ 355 feet to 405 feet ~~P~~ S
405 425

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 445 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature COLD °F Quality TBD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CRK RD (Contractor)
CARSON CITY, NV 89704

Nevada contractor's license number issued by the State Contractor's Board 13697A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790

Signed Joe Leisch (By driller performing actual drilling on site or contractor)
Date 8/19/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627