



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21616

1. OWNER BARRICK GOLD STRIKE MINE ADDRESS AT WELL LOCATION P.O. BOX 29, EIKO NV.  
 MAILING ADDRESS P.O. BOX 29, EIKO NV.

2. LOCATION SE 1/4 SW 1/4 Sec. 9 T. 34N N/S R. 49E E. EUREKA County  
 PERMIT NO. 1026 DISPOSAL Parcel No. Boulder Valley Dewatering Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Moist brn clay w/ silt	B.5	0'	14'	14'
MOIST-WET BRN clay w/ silt MIX blk sands		14'	48'	
HARD GRAY clay		48'	52'	4'
Silty clay w/ blk sand		52'	58'	6'
COURSE SANDS & GRAVEL		58'	61'	3'
lt brn clay w/ silt		61'	95'	34'
lt. yellow, green hard clay		95'	102'	7'

8. WELL CONSTRUCTION  
 Depth Drilled 102 Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 0 Feet 102 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	N/A	40SCH	0'	75'
2"		40SCH	0'	15'

Perforations:  
 Type perforation LT Factory slot  
 Size perforation .02 SLOT  
 From 75' feet to 95' feet  
 From 35' feet to 15' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 70' / 36.5' feet to 97' / 13' feet

9. WATER LEVEL  
 Static water level 8.5' feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality N/A

Date started 8-4-96, 1996  
 Date completed 8-5-96, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Robert W. Charbeneau Contractor  
 Address 10281 BOUVARIS Rd Ana Ca Contractor  
BEYLIK DRILLING INC  
 Nevada contractor's license number issued by the State Contractor's Board 0007053A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2016  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-10-96

