WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 53289
Permit No.
Basin 162

NOTICE OF INTENT NO. 14706

1. OWNER Don & Laurie Langston
MAILING ADDRESS
ADDRESS AT WELL LOCATION 281 E. Bonita Ave.

2. LOCATION SE ¼ NW ¼ Sec. 34 T. 19-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 29-852-03 (Parcel No.) Rancho Del Sol, Unit 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay		4	18	14
Brown clay/caliche		18	28	10
Brown clay		28	44	16
Brown clay/caliche		44	56	12
Brown clay/caliche/ gravel		56	72	16
Brown clay		72	84	12
Brown clay/caliche	X	84	104	20
Limestone		104	110	6
Brown clay	X	110	128	18
Brown clay/caliche	X	128	178	50
Brown clay/caliche/ gravel		178	200	22

RECEIVED
MAY 11 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 4, 19 95
Date completed May 4, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	½

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	200

Perforations:
Type perforation Torch Cut
Size perforation ¼" width 8" long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 80 feet to 200 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC (Contractor)
Address P.O. Box 56 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1812
Signed (By driller performing actual drilling on site or contractor)
Date May 8, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627