



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17441

1. OWNER RHODES HOMES ADDRESS AT WELL LOCATION 7014 W WARM SPRINGS RD  
 MAILING ADDRESS \_\_\_\_\_ RAINBOW + WARM SPRINGS

2. LOCATION SE 1/4 SE 1/4 Sec. 3 T. 22 N/S R. 60 E CLARK County  
 PERMIT NO. 176-03-801-011 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND, GRAVEL & ROCKS.		0	50	50
CMT. GRAVEL w/ STRKS OF CLAY & GRAVEL.		50	450	400
SANDSTONE.	505	450	560	110
CMT. GRAVEL w/ STRKS SANDSTONE.	✓	560	650	90

8. WELL CONSTRUCTION  
 Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
9 7/8 Inches 0 Feet 200 Feet  
8 1/2 Inches 200 Feet 650 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 5/8</u>	<u>10.9</u>	<u>.188</u>	<u>+1</u>	<u>650</u>

Perforations:  
 Type perforation FACTORY SAW.  
 Size perforation 18 x 2 1/2  
 From 590 feet to 630 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 650 feet

9. WATER LEVEL  
 Static water level: 441 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DESERT DRILLING Contractor  
 Address 6475 GARY AVE Contractor  
LAS VEGAS, NV. 89139

Nevada contractor's license number issued by the State Contractor's Board: 34274  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1594

Signed Symonell Couch  
 Driller performing actual drilling on site or contractor  
 Date 9-6-96

Date started 9-3, 1996  
 Date completed 9-6, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

