


OFFICE USE ONLY
Log No. 53913
Permit No. 163
Basin. 163



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Jim Stevens, Jr. ADDRESS Goodsprings, Nevada

2. LOCATION 1/4 NE 1/4 Sec. 26 T. 24 N/S.R. 58 E. Clark County
PERMIT NO. Domestic

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Broken Brown Line with layers of Redish Clay one to three ft. thick		0	179	
Reddish Brown Sandy Clay Bearing Water		179	193	

8. WELL CONSTRUCTION
Diameter hole 12 1/2 inches Total depth 193 feet
Casing record
Weight per foot Thickness 10G
Diameter 8 inches From +1 feet To 193 feet
Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 193 feet to 50 feet
Perforations:
Type perforation Cutting Torch
Size perforation 1/8" X 18"
From 193 feet to 118 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

RECEIVED

OCT 30 1969

DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started 9/15, 1969
Date completed 10/6, 1969

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
Static water level 118 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Address 5434 W. Alexander
Nevada contractor's license number 10062
Nevada driller's license number
Signed Vernon H. Dimick
Date 10/28/69

BAILER TEST

G.P.M.	Draw down	feet	hours