

OFFICE USE ONLY  
Log No. 54608  
Permit No. \_\_\_\_\_  
Basin. 212



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16819

1. OWNER Sundt Corp ADDRESS AT WELL LOCATION On Tustin  
MAILING ADDRESS 2950 E Flamingo W 82 Annie Oakley  
LV NV 89121

2. LOCATION SW 1/4 - 1/4 Sec 18 T 21 N34R 62 E County \_\_\_\_\_  
PERMIT NO. DW 1060 Issued by Water Resources Parcel No. 161-18-499-050 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE dewater WELL TYPE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC/  
 Municipal/Industrial  Monitor  Stock  Air  Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>		<u>0</u>	<u>6"</u>	<u>6"</u>
<u>Fill</u>		<u>6"</u>	<u>3</u>	<u>2"</u>
<u>Clay</u>		<u>3</u>	<u>16</u>	<u>13</u>
<u>Caliche gravel</u>		<u>16</u>	<u>19</u>	<u>3</u>
<u>sand + gravel</u>		<u>19</u>	<u>21</u>	<u>2</u>
<u>Sandy Clays</u>		<u>21</u>	<u>40</u>	<u>19</u>

8. WELL CONSTRUCTION  
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
From 24 Inches To 40 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>40</u>

Perforations:  
Type perforation Slot  
Size perforation 20 3/8  
From 12 feet to 30 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 0 feet to 90 feet

9. WATER LEVEL  
Static water level 15 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60 °F Quality good

Date started 8-27 1996  
Date completed 8-27 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GDC Contractor  
Address 536 E Midland Contractor  
Ontario CA

Nevada contractor's license number issued by the State Contractor's Board: 0031246  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: W 1968

Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 9-5-96