



Log No. 54010  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16019

1. OWNER Sundt Corp. ADDRESS AT WELL LOCATION On Tustin @ Annie Oakley  
 MAILING ADDRESS 2950 F. Flamingo @ Annie Oakley  
LU NO 87121  
 2. LOCATION SW 1/4 - 1/4 Sec 18 T 21 S R 62 E Clark County  
 PERMIT NO. DW 1060 Issued by Water Resources Parcel No. 161-18-499-011 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE dewater WELL TYPE  
 Domestic  Irrigation  Test  Cable  Rotary  RVG  
 Municipal/Industrial  Monitor  Stock  Air  Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		6'	6'	6'
Fill		6'	3'	3'
Clay		3'	12'	9'
Caliche		12'	16'	4'
Sand & gravel		16'	18'	2'
Sandy clay		18'	40'	22'

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>54</u>	<u>40</u>	<u>PUC</u>	<u>0</u> to <u>4</u>

Perforations:  
 Type perforation slot  
 Size perforation 003 #  
 From 10 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No 40  
 From 0 feet to 40 feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 66.1 °F Quality good

Date started 8-22, 1996  
 Date completed 8-22, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GDC Contractor  
 Address 536 E. Mainland Contractor  
Ontario CA  
 Nevada contractor's license number 0031246  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the M-1969  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9-5-96