DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 54189
Permit No.
Basin 212

1. OWNER Joe Farber ADDRESS Top of Wonder Spring Summit Behind Bragins Property
2. LOCATION ¼ ¼ Sec. 19 T. 22 N/S R. 58 E. Clark County
PERMIT NO. Domestic

3. TYPE OF WORK: (New Well) ☐ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: (Domestic) ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ (Rotary) ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil & Rocks		0	10	10
Yellow Clay		10	17	07
Clay w/ small Embedded Clay		17	31	14
Hard Rock	X 78	31	100	69
Red Sand Rock streak of Clay	✓	100	130	30
Hard Rock	✓	130	151	21
Sandy Clay with Rock	✓	151	162	11
Hard Rock		162	170	08
Sandy Clay		170	174	04
Sandy Clay w/ streak of Hard Rock		174	200	26

RECEIVED
AUG 2 1971
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started 6-8 19 71
Date completed 7-25 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 200 feet
Casing record 8 5/8
Weight per foot 10-75 Thickness 109 ga
Diameter 8 5/8 inches From 0 feet To 201 feet
..... inches From ..... feet To ..... feet
..... inches From ..... feet To ..... feet
..... inches From ..... feet To ..... feet
..... inches From ..... feet To ..... feet
..... inches From ..... feet To ..... feet
Surface seal (Yes) ☐ No ☐ Type Cement
Depth of seal 50 Ft. feet
Gravel packed: (Yes) ☐ No ☐
Gravel packed from 50 feet to 201 feet

Perforations:
Type perforation Torch Cut
Size perforation 1/4" x 6" x 3 Rounds
From 60 feet to 201 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 71 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ray Floyd Pump Co.
Address P.O. Box 157 Pahrump
Nevada contractor's license number 7479
Nevada driller's license number 476
Signed Jerry E. Floyd
Date 7/27/71

USE ADDITIONAL SHEETS IF NECESSARY

5471

1