WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54203
Permit No.
Basin 162

NOTICE OF INTENT NO. 14934

1. OWNER Leonard & Alice Rodowick
MAILING ADDRESS 4021 Norway Dr.
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
4021 Norway Drive

2. LOCATION SE 1/4 SW NW 1/4 Sec. 32 T 20 N/S R 54E E Nye County
PERMIT NO. Issued by Water Resources
27-471-44 Parcel No.
Green Saddle Ranch Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT LOAM		0	18	18
GREY CLAY		18	38	20
GREY POPCORN		38	50	12
DARK GREY POPCORN	X	50	69	19
GREY POPCORN	X	69	85	16
GREY CLAY	X	85	102	17
LIGHT BROWN CLAY	X	102	125	23
LIGHT BROWN CLAY	X	125	143	18
LIGHT BROWN CLAY	X	143	160	17

Date started 8/29/96, 19__
Date completed 8/30/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	NA	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	160

Perforations:
Type perforation TORCH
Size perforation .25 X 6
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 110 feet to 160 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address HC 78 BOX 80036 Contractor
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date September 3 1996

SEP 4 1996 OFFICE