WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54215
Permit No.
Basin 162

NOTICE OF INTENT NO. 17791

1. OWNER Strickland Construction Co., Inc.
MAILING ADDRESS HC 78 Box 80036
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
4350 E Mary Lou

2. LOCATION SW 1/4 NW 1/4 Sec. 17 T 21S N/S R 54E E Nye County
PERMIT NO. _____ Issued by Water Resources | 45-181-30 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	16	16
BROWN CLAY		16	34	18
BIEGE CLAY		34	50	16
BROWN POPCORN	X	50	69	19
GREY CLAY	X	69	88	19
GREY CALICHIA	X	88	104	16
LIGHT BROWN CALICHIA	X	104	120	16
BROWN CLAY	X	120	145	25

SEP 23 1996

Date started 5/29/96, 19__
Date completed 5/30/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n\a	.50

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	145 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	145

Perforations:
Type perforation torch
Size perforation .25 x 6
From 105 feet to 125 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor

Address HC 78 BOX 80036
Contractor

PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Jerry Strickland
By driller performing actual drilling on-site or contractor

Date 9-18-96