DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 54269
Permit No.
Basin 163

1. OWNER ROBERT WERLY ADDRESS 5225 PORTIAL PLACE LAS VEGAS NEV. 89104
MOUNTAIN SPRINGS

2. LOCATION SE ¼ SW ¼ Sec. 20 T. 22 N/S R. 58 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GREY LIME		0	28	28
GRAVEL		28	36	8
LIME		36	53	17
SAND & GRAVEL		53	62	9
DARK LIME		62	112	50
FRACTURED LIME	✓	112	131	19
LIME		131	171	40
FRACTURED LIME	✓	171	192	21
LIME		192	200	8

RECEIVED
OCT 18 1973
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 4-17, 1972
Date completed 5-4, 1972

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 28 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 200 feet
Casing record 8 5/8
Weight per foot 18.9 Thickness 10 GA

Diameter	From	To
8 5/8 inches	0 feet	209 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations: TORCH
Type perforation 1/4 X 4 - 4 AROUND
Size perforation ON 16" CENTERS
From 110 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 95 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN WATER WELL SERVICE
Address P.O. BOX 15149 L.V. 89114
Nevada contractor's license number 5095
Nevada driller's license number 40
Signed [signature]
Date 5-11-72

USE ADDITIONAL SHEETS IF NECESSARY

5471

ع٥١ 1