

Log No. 54459
 Permit No. 212
 Basin 212

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. XXXX 1268

PRINT OR TYPE ONLY

1. OWNER John Meisner ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SE ¼ SW ¼ Sec. 14 19 T. 22 N S R 60 E clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand and gravel		0	63	63
red clay		63	98	35
cemented congom.		98	104	6
clay & Gravel		104	171	67
sand & gravel		171	205	34
clay & gravel		205	227	22
caving gravel		227	266	39
fractured cemented conglomerate		266	420	154
loose gravel	X	420	553	133
hard clay & gravel		553	561	8
gravel	XX	561	568	7
clay		568	600	32

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 600 feet
 Casing record 6-5/8"
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6-5/8"</u> inches	<u>0</u> feet	<u>600</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Torch
 Size perforation 1/8 x 4 " 3 around
 From 400 feet to 600 feet
 From _____ feet to _____ feet

RECEIVED
 SEP 20 1984
 Div. of Water Resources
 Branch Office - Las Vegas, Nev.

Date started May 27 1984
 Date completed June 12 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Air</u>	<u>50</u>	<u>?</u>	<u>1 hour</u>

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 388 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Allen Drilling Inc. Contractor
 Address 4847 So. Valley View Contractor
 Nevada contractor's license number 018917
 Nevada contractor's drillers number 1301
 Nevada driller's license number 1376
 Actual Driller
 Signed _____ Contractor
 Date September 18, 1984