62188-J - 62189-J (49716)

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54665
Permit No. 62190
Basin 162

NOTICE OF INTENT NO. 15276

1. OWNER Richard + Beth Rogers Trust
MAILING ADDRESS
ADDRESS AT WELL LOCATION Homestead Rd.

2. LOCATION NW ¼ SE ¼ Sec. 13 T. 21S N/S R. 53 E. NYE County
PERMIT NO. LI-465 (Issued by Water Resources) 44561-03 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay.		0	25	25
Caliche.		25	27	2
Clay.		27	45	18
Caliche.		45	48	3
Clay.		48	55	7
Caliche.	Trace.	55	58	3
Clay.		58	75	17
Caliche.	WB.	75	79	4
Clay		79	90	11
Caliche.	WB	90	93	3
Clay		93	108	15
Caliche.	WB	108	110	2
Clay		110	116	6
Caliche.	WB	116	119	3
Clay		119	130	11
Caliche.	WB	130	133	3
Clay.		133	145	12
Caliche.	WB	145	149	4
Clay		149	160	11
Caliche.	WB	160	163	3
Clay		163	185	22
Caliche.	WB	185	188	3
Clay		188	200	12
Caliche.	WB.	200	210	10
Clay		210	215	5
Caliche	WB.	215	220	5
Clay		220	230	10
Caliche.		230	235	5
Next Page				

Date started 7-10, 1996
Date completed 8-15, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
500	153	24 hr.
650	223	Draw Down
		in 30 min
		after 500
		GPM test.

SEP 5 1996

8. WELL CONSTRUCTION
Depth Drilled 490 Feet Depth Cased 490 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20 Inches		0 Feet	490 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	+1	490

Perforations:
Type perforation SAW.
Size perforation 1/8 inch by 3 inch
From 90 feet to 490 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 490 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1963
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54665
Permit No.
Basin 162

NOTICE OF INTENT NO. 15216

1. OWNER Richard + Beth Rogers Trust
MAILING ADDRESS
ADDRESS AT WELL LOCATION Homestead Rd.

2. LOCATION NW ¼ SE ¼ Sec. 13 T. 21S N/S R. 53 E. Nye County
PERMIT NO. W-465 (Issued by Water Resources) Parcel No. 44-561-03 Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		235	245	10
Calichie		245	260	15
Clay		260	290	30
Calichie		290	305	15
Clay		305	360	55
Calichie		360	365	5
Clay		365	390	25
Calichie		390	395	5
Clay		395	435	40
Calichie		435	442	7
Clay		442	455	13
Gravel		455	470	15
Clay		470	490	20

SEP 5 1996

Date started 7-10, 1996
Date completed 8-15, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
500	153	24 hr
650	223	Draw Down
		IN 30 min
		Open 500
		GPM test

8. WELL CONSTRUCTION
Depth Drilled 490 Feet Depth Cased 490 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
20	0	490

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	+1	490

Perforations:
Type perforation SAW
Size perforation 1/8 inch by 3 inch
From 90 feet to 490 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 490 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address P.O. Box 4220 Contractor
Pahrump NV. 89041
Nevada contractor's license number 30880 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1963
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-30-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627