

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15362

1. OWNER TRITON AIR HOLDING ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6688 SOUTH CENTRAL  
EXTENSION SOUTH DANA, TERN 28201  
 2. LOCATION NE 1/4 NW 1/4 Sec 33 T. 21 N. S. R. 61 E County CLARK  
 PERMIT NO. MO-2709 Parcel No. 162-33-101-009 Subdivision Name NA CARSON AIRPORT  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>MLW-10.5</u>		<u>61</u>	<u>40</u>	<u>21</u>
<u>TREMIE GROUTED W/CEMENT IN 20' LINTS</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 61 Feet Depth Cased 60 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>				

Perforations:  
 Type perforation MACHINE STOPPED  
 Size perforation \_\_\_\_\_  
 From 60 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Scal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 119.9 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 6-4-96, 19\_\_\_\_  
 Date completed 6-4-96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name HYDRO-SEARCH INC Contractor  
 Address 50 WEST HIDENTY ST Contractor  
SUITE 500 RENO NV 89501  
 Nevada contractor's license number issued by the State Contractor's Board 0038915  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller -171  
 Signed H.V. Wegner  
 By driller performing actual drilling on site or contractor  
 Date 6-4-96