WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 54731
Permit No.
Basin 163

#1635

1. OWNER Tom Fitzharris ADDRESS Box 115 HCR 70 JEAN, NEVADA 89019

2. LOCATION SW ¼ SE ¼ Sec. 32 T. 24.5 N/S R. 57 E. CLARK County
PERMIT NO. APN # 201-32-801-010

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALUVIAL FILL		0	111	111
CLAY		111	117	6
SANDY CLAY		117	128	11
ROCK & GRAVEL		128	140	12

RECEIVED
SEP 10 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Aug 10, 1984
Date completed Sept 7, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 2 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 14 inches Total depth 140 feet
Casing record Steel
Weight per foot 12.5 Thickness .156

Diameter	From	To
8 5/8 inches	Surface feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation FLAME CUT 4 Row 16" Centers
Size perforation 3/8 X 4"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 87 Feet below land surface 87
Flow G.P.M.
Water temperature 70 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ROBERT SPURLOCK
Address Box 610 HCR 70 JEAN NEV 89019
Nevada contractor's license number 020301
Nevada driller's license number 1352
Signed Robert Spurlock
Date Sept 8-84

USE ADDITIONAL SHEETS IF NECESSARY

O-627