WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 54781 In Book
Permit No.
Basin 212

1. OWNER Irene Ferguson WELL ADDRESS 6480 W. Russell

2. LOCATION NW ¼ NE ¼ Sec. 35 T. 21S N/S R 60 E. Clark County
PERMIT NO. PARCEL # 163-35-501-001

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0	1	
gravel-cemented				
to loose		1	460	
water @ 370				

RECEIVED JAN 16 1980 Div. of Water Resources Branch Office — Las Vegas, Nev.

Date started 1-11, 1980
Date completed 1-15, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼-11 inches Total depth 460 feet
Casing record
Weight per foot 14.5 Thickness .156

Diameter	From	To
8 inches	+1 feet	460 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation machine
Size perforation 1/8" X 2½"
From 382 feet to 405 feet
From 425 feet to 445 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 312 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name drlg. & Pumps Inc.
Address Henderson, Nevada
Nevada contractor's license number 6294 A
Nevada driller's license number 693
Signed M. D. Brown
Date January 15, 1980

USE ADDITIONAL SHEETS IF NECESSARY

O-627