


1 1/2 Book

OFFICE USE ONLY
 Log No. 54768
 Permit No. 212
 Basin 212



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert Boyer #2 ADDRESS 5425 West Teco, L.V.

2. LOCATION SW 1/4 SE 1/4 Sec. 36 T. 21S N/S R. 60 E Clark County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------------|--------------|------|-----|------------|
| Loose Gravel | | 0 | 6 | |
| Cemented Gravel | | 6 | 12 | |
| Gravel clay sand (reddish) | | 12 | 98 | |
| Cemented Gravel | | 98 | 165 | |
| Gravel Clay Sand | | 165 | 210 | |
| Cemented Gravel | | 210 | 340 | |
| Cemented Gravel & Water | | 340 | 400 | |

RECEIVED

APR 15 1981

Div. of Water Resources
 Tech Office

8. WELL CONSTRUCTION
 Diameter hole 12 1/4 inches Total depth 400 feet
 Casing record _____
 Weight per foot _____ Thickness 10ga

| Diameter | From | To |
|---------------------|----------------|-----------------|
| <u>8 5/8</u> inches | <u>+1</u> feet | <u>400</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type Cement
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Torch
 Size perforation 1/4" X 18"
 From 300 feet to 400 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 260 Feet below land surface
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

Date started April 3, 19 81
 Date completed April 4, 19 81

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H Dimick
 Address 4131 Bradley RD, L.V.
 Nevada contractor's license number 10062
 Nevada driller's license number 552
 Signed V.H. Dimick
 Date April 13, 1981