LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6 5/8" O.D.	145	300	155	Wild 6" linner, telescoped 5 Ft. up in the 8" Casing

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Baling test indicates that well will deliever, approx 80 G.P.M. having a draw-down to 122 Ft. (consider very good)

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Douglas Slade
Well Driller

By Douglas Slade

License No. 137

Dated Sept. 2nd., 19 66

(Not to be filled in by Driller)