WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 54860
Permit No.
Basin 212

In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8575

1. OWNER Wayne Champlin
MAILING ADDRESS
ADDRESS AT WELL LOCATION UNK.

2. LOCATION NE ¼ NE ¼ Sec. 22 T. 22 N OR. 60 E CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay + Boulders | | 0 | 360 | 360 |
| Clay Stone | | 360 | 515 | 155 |
| Consolodated gravel | x | 515 | 570 | 55 |
| Clay Stone | | 570 | 600 | 30 |

RECEIVED
DEC 10 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-30, 19 90
Date completed 12-6, 19 90

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Air Test - 30 gpm | | | |
| 900 CFM @ 250 psi @ 600' | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 9 7/8 inches Total depth 600 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

| Diameter | From | To |
|---|---|---|
| 6 inches | + 1½ feet | 600 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 600 feet

Perforations:
Type perforation Torch
Size perforation ¼ x 10
From 516 feet to 600 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 390 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cool °F Quality ok

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dean Mitchell (Contractor)
Address 630 Rettig Ave L.V. Nev. 89124 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 27030
Nevada contractor's driller's number issued by the Division of Water Resources 1475
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed Floyd Mitchell (By driller performing actual drilling on site or contractor)
Date 12-8-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627