DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 54869
Permit No.
Basin 212

1. OWNER WALT ROSETTE ADDRESS 7050 W. PEBBLE ROAD L.V.

2. LOCATION NE ¼ NE ¼ Sec. 22 T. 22 N/S R. 60 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY & GRAVEL		0	432	432
RED CLAY		432	434	2
CEMENTED GRAVEL	✓	434	446	12
RED CLAY		446	454	8
CEMENTED GRAVEL		454	465	
GREY LIME		465	489	24
WATER SAND & GRAVEL	✓	489	502	13
CEMENTED GRAVEL		502	508	6

RECEIVED
MAY 1 1972
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started 12-23, 1971
Date completed 2-22, 1972

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 2 feet 1½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 508 feet
Casing record 8 5/8 — 10 GA
Weight per foot 12.20 Thickness 10 GA

Diameter	From	To
8 5/8 inches	0 feet	508 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation TORCH
Size perforation 1/4 x 5 4 AROUND 18" ¢
From 410 feet to 508 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 415 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN WATER WELL SERVICE
Address 4847 VALLEY VIEW L.V.
Nevada contractor's license number 5095
Nevada driller's license number 40
Signed [signature]
Date 3-2-72

USE ADDITIONAL SHEETS IF NECESSARY

5471