WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 54937
Permit No.
Basin 107

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 27422

1. OWNER John [illegible]
MAILING ADDRESS Box 378 Meeting [illegible]
ADDRESS AT WELL LOCATION [illegible]

2. LOCATION NW ¼ SE ¼ Sec. 32 T. 16 N/S R. 24 E. Lyon County
PERMIT NO. none (Issued by Water Resources) 10-761-[illegible] (Parcel No.) none (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	50	50
gravel & [illegible]	rock	50	120	70
[illegible]				
& rock		120	160	40
gravel & rock	yes	160	205	45
[illegible]				
& rock		205	320	115
gravel & rock	yes	320	340	20
solid rock		340	355	15

RECEIVED
96 SEP 10 AM 11:31
STATE ENGINEERS OFFICE

Date started April 15, 1996
Date completed Aug 20, 1996

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	6	60	5 hrs

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 355 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness 18[illegible]

Diameter	From	To
6 5/8 inches	0 feet	270 feet
5 5/8 inches	270 feet	340 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation factory [illegible]
Size perforation 3/32 x 3
From 200 feet to 340 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 290 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature [illegible] °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address Box 92 Smith [illegible] 8[illegible] (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada contractor's driller's number issued by the Division of Water Resources 718
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Sept 3, 1996

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627