WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54943
Permit No.
Basin 165

NOTICE OF INTENT NO. 24750

1. OWNER RED SUN + SAND DEVELOPMENT
MAILING ADDRESS MINDEN, NV
ADDRESS AT WELL LOCATION 1368 RABBITBRUSH GARDNERVILLE

2. LOCATION NW ¼ NE ¼ Sec. 1 T. 12 N/S R. 20 E. DOUGLAS County
PERMIT NO. — Issued by Water Resources
23-480-95 Parcel No.
WILDFLOWER Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY/GRAVEL		40	81	41
CLAY		81	93	12
SANDY CLAY/GRAVEL		93	111	18
GRAVEL/SAND		111	124	13
SANDY CLAY/GRAVEL		124	130	6
GRAVEL/SAND		130	244	114
CLAY		244	252	8
SANDY CLAY/GRAVEL		252	255	3
SAND GRAVEL		255	257	2
CLAY		257	264	7
CEMENTED GRAVEL		264	268	4
SANDY CLAY		268	276	8
CLAY		276	283	7
SANDY CLAY		283	310	27
SAND/CLAY/GRAVEL	✓	310	330	20
CLAY		330	356	26
SAND/CLAY/GRAVEL	✓	356	359	3
CLAY		359	360	1

RECEIVED 96 SEP 25 AM 11:53 STATE ENGINEER'S OFFICE

Date started 8-27, 1996
Date completed 9-12, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	257	—	2

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	360 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	360

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 1/8
From 320 feet to 340 feet
From 355 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. Contractor
Address 879 RITTER DR. Contractor
GARDNERVILLE, NV 89410
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-12-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627