



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2712

PRINT OR TYPE ONLY

1. OWNER Larry Hanks ADDRESS AT WELL LOCATION 687 Upper Canyon Rd. Wellington Nev. 89444  
 MAILING ADDRESS 687 Upper Canyon Rd. Wellington Nev. 89444  
 2. LOCATION NE 1/4 S.W. 1/4 Sec. 34, T. 12 N/S R. 23 E. Lyon County  
 PERMIT NO. none Issued by Water Resources Parcel No. 10-071-02 Subdivision Name none

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>brown clay</u>		<u>3</u>	<u>65</u>	<u>62</u>
<u>brown sand</u>	<input checked="" type="checkbox"/>	<u>55</u>	<u>235</u>	<u>180</u>
<u>brown clay + sand</u>	<input checked="" type="checkbox"/>	<u>235</u>	<u>270</u>	<u>35</u>
<u>blue clay + sand</u>	<input checked="" type="checkbox"/>	<u>270</u>	<u>270</u>	<u>5</u>
<u>brown clay + coarse sand</u>		<u>275</u>	<u>290</u>	<u>15</u>

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 290 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 5/8  
 Weight per foot \_\_\_\_\_ Thickness 188  
 Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement grout  
 Depth of seal 60 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 x 3  
 From 270 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 96 SEP 24 AM 11:29  
 STATE ENGINEERS OFFICE

Date started June 20 1996  
 Date completed Sept 15 1996

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>20</u>	<u>0</u>	

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Contractor  
 Address Box 92 Smiths Per. 89430 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada contractor's driller's number issued by the Division of Water Resources 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Miller  
 By driller performing actual drilling on-site or contractor  
 Date Sept 17 96