WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 54955
Permit No.
Basin 104

NOTICE OF INTENT NO. 30030

1. OWNER Buildings and Grounds - Nevada
MAILING ADDRESS Capitol Complex
406 E. 2nd. St. Carson City, NV. 89710

ADDRESS AT WELL LOCATION SE Corner 5th and Stewart
Carson City, NV.

2. LOCATION NE ¼ SW ¼ Sec. 17 T. 15 N/S R. 20 E Carson City County
PERMIT NO. 74876 (Issued by Water Resources) 4-022-01 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pump was removed from well and video was conducted. Depth of well was 435' we bailed sand from well to a depth of 590 ft.. We then perforated top 80' of 18" casing with Mills knife. Tremme pipe was installed to 583'. We pumped in 14 yds. of 8 sack sand grout wich brought the cement up to 83'. We then pumped in 6 yds of neat cement which brought the cement to 1' below ground surface. After cement had cured we cut casing off 3' below ground level.				

RECEIVED
96 SEP -9 AM 11:01
STATE ENGINEERS OFFICE

Date started August 23, 19 96
Date completed August 30, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 10' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address 1401 North Roop St. (Contractor)
Carson City, NV. 89701

Nevada contractor's license number issued by the State Contractor's Board 0039920

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed Dan Trampe (By driller performing actual drilling on site or contractor)

Date August 31, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627