

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31615
JULIAN LANE
WABUSKA, NV

1. OWNER TAO'S Enterprises ADDRESS AT WELL LOCATION JULIAN LANE
 MAILING ADDRESS 3535 Southampton DR
RENO NV. 89509
 2. LOCATION NE 1/4 SE 1/4 Sec. 16 T 15 R 25 E Lyon County
 PERMIT NO. MO 907 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>PULL COVER</u>				
<u>MIN pipe</u>				
<u>Break Bottom END OFF pipe</u>				
<u>Pull pipe</u>				
<u>Fill PVC w/ cement</u>				
<u>Pull PVC</u>				
<u>pipe is tremie to ANNULUS</u>				
<u>Fill as pulling</u>				
<u>Fill to GS</u>				

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)
 From 8" To 0
 Inches Feet
 Feet Feet
 Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.37</u>		<u>set 40</u>	<u>0</u>	<u>5</u>

Perforations:
 Type perforation SLOT
 Size perforation

From 5 feet to 20 feet
 From 5 feet to 20 feet
 From 5 feet to 20 feet
 From 5 feet to 20 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 20
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 5 feet to 20 feet

RECEIVED
 96 SEP +4 AM 10:33
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 8.7 1996
 Date completed 8.9 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA Drilling Inc Contractor
 Address 75 Lewers Creek RD Contractor
Carson City NV

Nevada contractor's license number 13697A
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller

Signed John L. Seibel
 By driller performing actual drilling on site or contractor

Date 8.21.96