WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

Washoe Co # 5917

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

OFFICE USE ONLY
Log No. 54973
Permit No.
Basin 088

NOTICE OF INTENT NO. 32005

1. OWNER Rick Lingelbach
MAILING ADDRESS 635 Placerville Dr. #416
Placerville, CA 95667

ADDRESS AT WELL LOCATION
16700 Mt. Rose Hwy. Reno, NV 89511

2. LOCATION NW 1/4 NW 1/4 Sec. 3 T 17N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 047-162-09 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We abandoned this well by first perforating using a Mills Knife from 90' to about 42' where we hit cement seal. We used about 2 yards of neat cement and pressure grouted from the bottom to the top. We perforated at about 4 perfs per each foot at 90 degrees to each other.				

RECEIVED 96 SEP 12 PM 12:00 STATE ENGINEER'S OFFICE

Date started 8/20/96, 19__
Date completed 8/20/96, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	116

Perforations:
Type perforation Mills Knife
Size perforation
From 90 feet to 42 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 8-20-96