

OFFICE USE ONLY  
 Log No. 55026  
 Permit No. 087  
 Basin                       
 51948

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51948

1. OWNER B+C BUILDERS SUPPLY ADDRESS AT WELL LOCATION SAME  
 MAILING ADDRESS 543 QUEZUMBER RD,  
SPARKS, NV.  
 2. LOCATION SW 1/4 SW 1/4 Sec 9 T 19 N3 R 20 E WASHOE County  
 PERMIT NO. 010 m/b 059511 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUSER

6. LITHOLOGIC LOG MWS

Material	Water Strata	From	To	Thick-ness
<u>ON 10/25/95</u>				
<u>I FOUND THE</u>				
<u>MONITORING WELL</u>				
<u>TO BE IN GOOD</u>				
<u>CONDITION. I THEN</u>				
<u>DRILLED OUT THE PVC</u>				
<u>CASINGS TO 33'</u>				
<u>I THEN PROCEEDED</u>				
<u>TO PRESSURE GRUNT</u>				
<u>THE WHOLE WITH</u>				
<u>NEAT CEMENT</u>				
<u>FROM 33' TO THE</u>				
<u>SURFACE</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 33' Feet Depth Cased 33' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6" Inches To 0' Feet 33' Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>40</u>	<u>PVC</u>	<u>0'</u>	<u>33'</u>

Perforations:  
 Type perforation FACTORY  
 Size perforation .020  
 From 15' feet to 33' feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 33'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From N/A feet to N/A feet

9. WATER LEVEL  
 Static water level 22.5 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature COLD °F Quality N/A

Date started 10/24 1995  
 Date completed 10/25 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDRESEN EXPLORATION DRILLING Contractor  
 Address 1635 BELFORD RD. Contractor  
RENO, NV. 89509  
 Nevada contractor's license number 34525  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1028  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 11/28/95