WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 53106
Permit No.
Basin 2-22

NOTICE OF INTENT NO. 19307

1. OWNER Michael B. Stewart
MAILING ADDRESS P.O. Box 40
Empire, Nev. 89405

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SE ¼ Sec. 24 T. 30N N/S R. 22 E. Washoe County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☑ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
The original well #2 was replaced. The original well made a lot of sand + gravel. We videoed the original well. Video went to 106 ft. We tried to clean out original well, with foam + air also gel. We never could make a connection at 110 ft. We spent 2 or 3 days trying to clean original well out. We were stuck in hole tore main box out of rig. We mixed approximately 40 SKs gel to a vis of 80-85 losing some circulation all the time. mixed six yds grout pumped in at 120 ft to surface. The next morning. Overnight grout ~~we~~ fell approximately down to 40-45 ft. Mixed 3 to 4 yds of concrete ¾ aggregate + sand poured cement to surface.				

Date started 8-19, 1992
Date completed 3-26, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		250		

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was ~~drilled~~ plugged under my supervision and the report is true to the best of my knowledge.
Name SAN Emidio Resources (Contractor)
Address P.O. Box 40 (Contractor)
Empire, Nev. 89405
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1558
Signed Michael W. Clark (By driller performing actual drilling on site or contractor)
Date 4-19-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627