LOG # 52128 (REPLACEMENT)
LOG # 55127 (PLUG)

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Permit No.
Basin 212

NOTICE OF INTENT NO. 17414

1. OWNER JAMES TAIPALE
MAILING ADDRESS

ADDRESS AT WELL LOCATION
5911 FANNINE

2. LOCATION NE ¼ SW ¼ Sec. 26 T. 19 N/S R. 60 E. CLARK County

PERMIT NO. (Issued by Water Resources) 01C-100-009-02 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY + CALICHE.		0	50	50
CLAY + CALICHE.		50	100	50
BROWN LIME		100	120	20
CLAY + CALICHE	220	120	310	190
CLAY + SANDY CLAY		310	400	90

OLD WELL SHEARED AT 186'

PUMPED NEAT CEMENT TO SURFACE

DCNR/DWR
MAY 24 1996
LAS VEGAS OFFICE

Date started 5-10, 1996
Date completed 5-16, 1996

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	400 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	60
6 5/8	12.92	.188	0	400

Perforations:
Type perforation FACTORY SAW.
Size perforation 1/8 X 2 1/2
From 340 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 400 feet

9. WATER LEVEL

Static water level 151 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WATER WELL SERVICES
Contractor
Address 6475 GARY AVE
Contractor
LAS VEGAS NV. 89139

Nevada contractor's license number issued by the State Contractor's Board 022311A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594

Signed Tyndall Couch
By driller performing actual drilling on site or contractor

Date 5-22-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627