WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25621
Permit No.
Basin

in Book

1. OWNER Paul Holland ADDRESS P.O. Box 4401 N.L.V. Nevada

2. LOCATION SW ¼ NE ¼ Sec. 20 T. T20S N/S R. 62 E. Clark County
~~PERMIT NO.~~ on 5/8 mile west of Nellis Blvd on Judson St - (South Side)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	81	81
Water Strata		81	83	2
Clay & Stringers of water in Series		83	200	117 (117)

RECEIVED
2 1978
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started April 10, 1978
Date completed April 21, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 46 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 200 feet
Casing record
Weight per foot 12.85 Thickness .144

Diameter	From	To
8 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Torch
Size perforation ⅛ x 12 inch
From 65 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 Feet below land surface
Flow G.P.M.
Water temperature Cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Douglas Slagle
Address 4518 E. Vegas Valley Dr. - LV
Nevada contractor's license number 3325
Nevada driller's license number 137
Signed Douglas Slagle
Date May 21, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471