

OFFICE USE ONLY
 Log No. 55913
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28127

1. OWNER Ralph Parish ADDRESS AT WELL LOCATION 699 Marion Wy Gardnerville NV 89410
 MAILING ADDRESS 699 Marion Wy Gardnerville NV 89410
 2. LOCATION SE 1/4 SW 1/4 Sec. 19 T. 12 S. R. 29 E. Douglas County
 PERMIT NO. 27-730-16 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Large Cabbles Embedded Gravels</u>		<u>0</u>	<u>45</u>	<u>45</u>
<u>Coarse Gravels</u>		<u>45</u>	<u>93</u>	<u>48</u>
<u>Coarse Cabbles Embedded Gravels</u>		<u>93</u>	<u>121</u>	<u>28</u>
<u>Soft Sandy Area</u>		<u>121</u>	<u>139</u>	<u>18</u>
<u>Coarse Red Gravels</u>		<u>139</u>	<u>160</u>	<u>21</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.23</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 160
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A. H. Pump Co. Contractor
 Address 5551 Hwy 50 E #3 Carson City NV 89701 Contractor
 Nevada contractor's license number 31839 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J. Halk
 By driller performing actual drilling on site or contractor
 Date 1-15-96

Date started 1-12 1996
 Date completed 1-15 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>35</u>	<u>3ARS</u>