

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

55921

Log No. _____

Rec. _____ 19__

Well No. _____

Permit No. _____

Do not fill in

Owner Thomas J. McLaughlin Driller Effinger Drill & Pump

Address 230 South Sixth Street Address 5488 W. Duncan Drive Lic. No. 212

Location of well: ENE NW 1/4 NE 1/4 Sec. 23, T 21 N/S, R 61 E, in Clark County

or Fleming Road

Water will be used for Domestic Total depth of well 200 feet

Size of drilled hole 12 Inch Weight of casing per linear foot _____

Thickness of casing 8 Gauge Temp. of water _____

Diameter and length of casing 8" ID 200 feet

(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure _____

If nonflowing well give depth of standing water from surface 35' from top of casing

If flowing well describe control works _____

(Type and size of valve, etc.)

Date of commencement of well September 30, 60 Date of completion of well October 6, 60

Type of well rig "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	10	10	Brown Clay & Gravel
10	20	10	Gyp
20	35	15	Red Sandy Clay & Gravel
35	45	10	Gyp
45	55	10	Brown Clay
55	58	3	Sand (Water)
58	75	17	Red Clay
75	84	9	Limestone (Water)
84	104	20	Red Clay
104	120	16	Sandy Clay
120	125	5	Sandstone
125	145	20	Brown Clay
145	153	8	Gravel (Water)
153	155	2	Red Clay
155	165	10	Decomposed Limestone (Water)
165	181	16	Red Clay
181	184	3	Limestone (Water)
184	190	6	Sandy Clay
190	193	3	Limestone (Water)
193	200	7	Red Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 155 to 165 ft.

Other aquifers 181-184

190-193

145-153

75-84

First water at 55 feet.


Casing perforated

from 100 to 200 ft.

Size of perforations

1/8" X 15"

LOG OF FORMATIONS—Continued



From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" ID	0	200	200	Cemented from 0 to 50 feet 2 yards of cement 5 yards of pea gravel Graveled packed from 50 to 200 feet

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill & Pump
Well Driller

By A. F. Effinger
License No. 212

Dated October 6, 1960

(Not to be filled in by Driller)
