WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 56372
Rec. ..... 19..
Well No. .....
Permit No. .....
Do not fill in

Owner: Louise W. Evans Driller: Louis P. Evans

Address: 2020 Carroll North Las Vegas Nevada Address: 2020 Carroll N. Las Vegas Nev Lic. No. 117

Location of well: N.E. ¼ N.W. ¼ Sec 34, T. 21 N/S, R. 61 E, in Clark County

or .....

Water will be used for: Domestic Total depth of well: 160 ft.

Size of drilled hole: 160 ft. 10 inch. hole Weight of casing per linear foot: 9.28 lbs.

Thickness of casing: 10 gauge Temp. of water: .....

Diameter and length of casing: 6 inch. I.D. pipe 160 ft.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure: .....

If nonflowing well give depth of standing water from surface: 10 ft.

If flowing well describe control works: .....
(Type and size of valve, etc.)

Date of commencement of well: March. 8, 1955 Date of completion of well: March. 11, 1955

Type of well rig: Armstrong

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	1	1	brown sandy clay
1	4	3	gravel
4	16	12	gyp
16	20	4	rock
20	28	8	gray clay & gravel (water)
28	30	2	gravel
30	46	16	brownsandy clay
46	47	1	gravel
47	53	6	brown clay
53	60	7	gravel
60	67	7	brown clay
67	68	1	gravel (water)
68	95	27	gray clay
95	96	1	gravel (water)
96	127	31	gray clay
127	134	7	yellow clay & gravel (water)
134	151	17	" sandy clay (water)
151	160	9	brown clay & gravel (water)

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 134 to 151 ft.

Other aquifers: 67 to 68
95 to 96 127 to 134
151 to 160

First water at 20 feet.

Casing perforated

from 160 to 160 ft.

Size of perforations

¼ inch wide 6 inches long

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6 inch.	0	160	160	gravel packed 110 ft. from 50 ft. to 160 ft. cemented 3½ yds. cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Louis F. Evans
Well Driller

By Louis F. Evans

License No. 117

Dated March 15, 19 55

(Not to be filled in by Driller)