WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57071
Permit No.
Basin 101

NOTICE OF INTENT NO. 30040

1. OWNER Btl Construction
MAILING ADDRESS 2161 W Williams Ave. Ste 279
Fallon, NV 89406

ADDRESS AT WELL LOCATION
5400 Bottom Road, Fallon, NV 84906

2. LOCATION NW 1/4 NE 1/4 Sec. 32 T 19N N/S R 19E 29E E Churchill County
PERMIT NO. _____ Issued by Water Resources | 8-652-31 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	16	16
Clay		16	24	8
Coarse Sand		24	33	9
Clay		33	44	11
Gray Clay		44	46	2
Gray Sand		46	63	17
Gray Clay		63	65	2
Brown Sand	X	65	80	15

RECEIVED OCT 3 1996 STATE ENGINEER'S OFFICE

Date started 9/23/96, 19__
Date completed 9/23/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	80 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	80

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 77 feet to 80 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 80 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454

Signed Norman Parsons
By driller performing actual drilling on-site or contractor

Date 10-1-96