

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33228

1. OWNER William Holland ADDRESS AT WELL LOCATION 1945 Spanish Spring Rd.
 MAILING ADDRESS 1945 Spanish Springs Rd. Sparks, NV 89436

2. LOCATION SW 1/4 NW 1/4 Sec. 27 T 20 S R 20 EAST WASHOE County
 PERMIT NO. 035-300-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cased with 6-5/8 to 90' start drilling at 90'</u>				
<u>Multi colored large volcanic rock soft</u>		<u>105</u>	<u>125</u>	
<u>Green & orange volcanic rock</u>		<u>125</u>	<u>160</u>	
<u>Greenish gray fractured rock</u>		<u>160</u>	<u>170</u>	
<u>Dark gray fractured volcanic rock</u>		<u>170</u>	<u>200</u>	
<u>T.D. 200'</u>				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 6-1/8 Inches To 9.0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>6.56</u>	<u>.188</u>	<u>80</u>	<u>200</u>

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal In place
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level: 30' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service Inc. Contractor
 Address 1800 1/2 Frazer Avenue Contractor
Sparks, NV 89431
 Nevada contractor's license number issued by the State Contractor's Board: 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1509T-1
 Signed Tony Welch
 By driller performing actual drilling on site or contractor
 Date Oct 11, 1996

Date started 9-27-96, 19_____
 Date completed 9-28-96, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>1 HR</u>

RECEIVED
 DIVISION OF WATER RESOURCES
 9-27-96 11:00 AM
 OFFICE