

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31168

1. OWNER Janice Pelt ADDRESS AT WELL LOCATION 992 E. ...
 MAILING ADDRESS 992 E. ...

2. LOCATION N 1/4 Sec 15 T 19 S R 19 E Washoe County
 PERMIT NO. 08042007 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D.F.		230	238	8
D.F. with sand	12	238	252	14
BLACK + WHITE GRANITE		252	325	72
BROKEN D.F. BLACK	20	325	345	20
Solid white Granite		345	350	5

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 350 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 3/8</u>	<u>16 1/2</u>	<u>188</u>	<u>-4</u>	<u>350</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 2" X 28"
 From 235 feet to 255 feet
 From 255 feet to 345 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 212 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 51 °F Quality FAIR

Date started 3-18, 19 96
 Date completed 3-21, 19 96

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>757</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name J M Drilling Contractor
 Address 1859 Hymer Ave Sparks NV 89431 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 41172
 Nevada driller's license number issued by the Division of Water Resources, on-site driller 1940
 Signed David E. Glander
 By driller performing actual drilling on site or contractor
 Date 3-27-96