WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 57087
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1755

1. OWNER Ron G. Izatt
MAILING ADDRESS 3211 Meade Ave.
Las Vegas, Nev. 89102

ADDRESS AT WELL LOCATION Schirlls and Cougar

2. LOCATION NE ¼ SW ¼ Sec. 18 T. 22 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented gravel		0	400	400

RECEIVED
NOV 30 1984
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Nov. 14, 1984
Date completed Nov. 27, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 400 feet
Casing record
Weight per foot ..... Thickness .156

Diameter	From	To
8 5/8 inches	+1 feet	390 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 400 feet

Perforations:
Type perforation Knife perforated
Size perforation 3/16x1½" 4 rows 4" center
From 320 feet to 390 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 261 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon Las Vegas, Nevada 89103 (Contractor)
Nevada contractor's license number 4286A
Nevada contractor's drillers number 582
Nevada driller's license number 1377 (J. Thompson) (Actual Driller)
Signed Richard K. Thompson (Contractor)
Date November 28, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

CORRECTED REPORT

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 57087
Permit No.
Basin 212

NOTICE OF INTENT NO. 1755

1. OWNER Ron G. Izatt
MAILING ADDRESS 3211 Meade Ave.
Las Vegas, Nevada 89102

ADDRESS AT WELL LOCATION On Ford near
Cameron (no number assigned yet)

2. LOCATION SW ¼ SW ¼ Sec. 18 T. 22 N/S R. 61 E Clark County
PERMIT NO. NE SW (2)
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented gravel		0	400	400

RECEIVED
DEC 10 1984
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started November 14, 19 84
Date completed November 27, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 400 feet
Casing record
Weight per foot ..... Thickness .156

Diameter	From	To
8 5/8 inches	+1 feet	390 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 400 feet

Perforations:
Type perforation Knife perforated
Size perforation 3/16x1½" 4 rows 4" center
From 320 feet to 390 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 261 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon, Las Vegas, Nevada 89103 (Contractor)
Nevada contractor's license number 4286A
Nevada contractor's drillers number 582
Nevada driller's license number 1377 (J. Thompson) (Actual Driller)
Signed Richard K. Thompson (Contractor)
Date Dec. 5, 1984 (Corrected report)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434