

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28043

1. OWNER Gary Hembree ADDRESS AT WELL LOCATION 1901 Pisano Hills Dr.
 MAILING ADDRESS 306 Ruby Ln. Carson City NV 89704
 2. LOCATION NE 1/4 SE 1/4 Sec. 23 T. 15 N. S. R. 20 E Carson County
 PERMIT NO. 10-102-05 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Coarse Gravels</u>		<u>3</u>	<u>27</u>	<u>24</u>
<u>Last Circulation</u>				
<u>Volcanic Sands</u>		<u>27</u>	<u>63</u>	<u>36</u>
<u>Brownish Red Clays</u>		<u>63</u>	<u>96</u>	<u>33</u>
<u>Volcanic Sands Imbedded</u>		<u>96</u>	<u>105</u>	<u>9</u>
<u>In Red Clays</u>				
<u>Volcanic Gravels</u>	<u>xxx</u>	<u>105</u>	<u>1100</u>	<u>55</u>

8. WELL CONSTRUCTION
 Depth Drilled 158 Feet Depth Cased 158 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 1/4 Inches 0 Feet 55 Feet
9 7/8 Inches 55 Feet 158 Feet
 Inches.....Feet.....Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>158</u>

Perforations:
 Type perforation M.II slot
 Size perforation 3 X 3/32
 From 138 feet to 158 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 158 feet

Date started 5-13 1996
 Date completed 5-15 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>30</u>	<u>3 HRS</u>

9. WATER LEVEL
 Static water level 9.5 feet below land surface
 Artesian flow..... G.P.M. 25 P.S.I.
 Water temperature 120+ °F Quality.....

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name A E H pump Company Contractor
 Address 5551 Hwy 50 E H3 Contractor
Carson City NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael L Haek
 By driller performing actual drilling on site or contractor
 Date 5-15-96