


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 57148  
 Permit No. \_\_\_\_\_  
 Basin 089



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32014

1. OWNER Jim Blueberg ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2970 Hawk  
Carson City, NV 89704 2300 Old Ranch Road

2. LOCATION SW 1/4 NW 1/4 Sec. 10 T. 16N N/S R 19E E Washoe County \_\_\_\_\_  
 PERMIT NO. Wa Co 5732 055-031-02  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	5	5
Brn sand & clay stringers		5	15	10
Coarse & fine brwn sand		15	40	25
White & brown rock		40	60	20
See next line		60	83	23
White rock w/blk & brn granite				
White clay		83	85	2
White & Brown rock		85	87	2
White clay		87	92	5
Red clay w/ rock		92	95	3
Grey clay		95	100	5
See next line	x	100	212	112
Hard fracture w/blk granite & white rock				
Red clay		212	215	3
Stained multi colored rock	xx	215	230	15

8. WELL CONSTRUCTION

Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>230</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>230</u>

Perforations:

Type perforation Factory  
 Size perforation 3/32 " x 3"

From	feet to	feet
<u>210</u>	<u>230</u>	
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 125

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 125 feet to 230 feet

9. WATER LEVEL

Static water level 16 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay  
 By driller performing actual drilling on site or contractor  
 Date 9-10-96

Date started 8/22/96 .19  
 Date completed 8/23/96 .19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>32</u>	<u>58</u>	<u>6 hrs</u>

RECEIVED  
 96 SEP 12 PM 12:00  
 STATE ENGINEERS OFFICE