WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

in Book

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 57317
Permit No.
Basin 212

1. OWNER Edward H Kopf Jr ADDRESS 9075 S. Procyon Ave Las Vegas

2. LOCATION NE ¼ NW ¼ Sec. 20 T. 22 S N/S R. 61 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray Cement Gravel		0	60	60
Brown " "		60	70	10
Gray " "		70	85	15
Red Clay		85	105	20
Gray Cement Gravel		105	195	90
Gray Gravel	X	195	255	60
Brown Gravel	X	255	300	45

RECEIVED
25 1978
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started April 24, 1978
Date completed May 8, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 0 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 300 feet
Casing record 8"
Weight per foot 12-15 Thickness .134

Diameter	From	To
8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50'
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 300 feet

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3
From 200 feet to 220 feet
From 240 feet to 260 feet
From 280 feet to 300 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 195 Feet below land surface
Flow G.P.M.
Water temperature 72 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vincent J Dresden
Address 2920 Beechwood Pl Las Vegas
Nevada contractor's license number 13577
Nevada driller's license number 968
Signed Vincent J Dresden
Date May 23 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471