

Log No. 57403

Permit No.

Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Frontier Fidelity
(Leonard Peterson)

ADDRESS 4815 E. Van Buren
Las Vegas, Nevada

2. LOCATION NE 1/4 N 1/2 Sec. 29 T. 20 N/SR. 62 E Clark County
PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay & silt		0	30	30
Clay with gravel (medium hard)		30	45	15
Red clay		45	63	17
Sandy clay with sand & s.stone ledges		63	150	87

Note: This was to replace old well which had a stucco house built over it.

RECEIVED
OCT 13 1968
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 150 feet
Casing record
Weight per foot _____ Thickness _____
Diameter 8 5/8 inches From 0 feet To 150 feet
_____ inches _____ feet _____ feet

Surface seal: Yes No Type Cement
Depth of seal 55 feet
Gravel packed: Yes No
Gravel packed from 55 feet to 150 feet

Perforations:
Type perforation slot - torch cut
Size perforation 1/4" x 6"
From 90 feet to 150 feet
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 77 Feet below land surface
Flow _____ G.P.M.
Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Drilling & Pumps, Inc.
3521 Spring Mountain Road
Address Las Vegas, Nevada 89102

Nevada contractor's license number 6294A
Nevada driller's license number 532

Signed Lloyd R. Lemon
Date 10/17/68

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 25 feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours