Deri: Please update Well Log D.B.! - Bobby D

DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 57527
Permit No.
Basin 212

I

~~NW~~ NWSE

1. OWNER Mike Gilliland ADDRESS 1745 Helm Drive

2. LOCATION ~~NW~~ SE. NW. ¼ ~~SE~~ ¼ Sec. 28 T. T22S N/S R. 61 E. Clark County
PERMIT NO. S.E. Corners of Pyle + Gillespie Streets

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Gravel + Sand		0	145	145
Rocks & Water	X	145	150	5
Red Clay + gravel		150	165	15
Brn Clay + gravel		165	181	16
Lt Brn Clay + gravel		181	188	7
Red Clay + Gravel		188	192	4
Water + Sand	X	192	194	2
Brt Red Clay + P-gravel		194	212	18
Lt Brn Clay + P-gravel		212	222	10
Hard Rock		222	224	2
Water + Rocks	X	224	227	3
Brn Clay + P-gravel		227	247	20
Hrd Clay + Rocks		247	250	3
Hrd Clay + P-gravel		250	288	38
Water + Sand	X	288	290	2
Sand + Clay		290	297	7

RECEIVED
JAN 27 1977
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Dec. 20, 1976
Date completed Jan 18, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 42 feet .5 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 297 feet
Casing record
Weight per foot 12.6 Thickness 10 gage

Diameter	From	To
8 5/8 inches	0 feet	297 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 297 feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 12 inch
From feet to feet
From 120 feet to 297 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 110 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Douglas Slagle
Address 6350 L.V. Blvd South L.V.
Nevada contractor's license number 3325
Nevada driller's license number 137
Signed Douglas Slagle
Date Jan 26 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471