



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14997

1. OWNER CRESSENZO RAPONE ADDRESS AT WELL LOCATION POTOMAC + LEAD  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION Southeast NW 1/4 Sec 26 T. 24 N. R. 56 E CLARK SANDY VALLEY NV. County  
 PERMIT NO. 580-250-042 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CALICHE		0	3	3
CLAY		3	15	12
CALICHE		15	20	5
CLAY		20	44	24
CALICHE		44	48	4
CLAY		48	60	12
CALICHE		60	68	8
CLAY		68	79	11
CALICHE	W.B	79	83	4
CLAY		83	96	13
CALICHE	W.B	96	102	6
CLAY		102	128	26
CALICHE	W.B	128	136	7
CLAY		136	140	4

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 8 INCH BY 3 INCH  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 140 feet to 50 feet

Date started 10-28, 1996  
 Date completed 10-30, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 63 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET DRILLING CO. Contractor  
 Address P.O. BOX 3505 SANDY VALLEY NV. 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 40021  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523  
 Signed Dannie Brown  
 By driller performing actual drilling on site or contractor  
 Date 10-30-96