

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9014

1. OWNER JUILO AGUILAR ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2121 WESTERN AV. WEST GOMMER
L.V. NEV 89102
 2. LOCATION NE 1/4 NE 1/4 Sec. 29 T. 22 N. R. 60 E. CLARK County _____
 PERMIT NO. 17629-50100497 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY + GRAVEL		0	10	10
Cemented gravel		10	230	220
Consolidated gravel		230	380	150
CLAY + Boulders		380	525	145
BRN CLAYSTONE		525	625	100
BRN SANDSTONE		625	725	100
BRN CLAYSTONE	MIN.	725	740	15
BRN SANDSTONE		740	805	65
GRAY LIMESTONE		805	810	5
Red CLAY + Boulders		810	890	80
Red CLAY		890	930	40
BRN CLAY w/ GRAVELS		930	1000	70

8. WELL CONSTRUCTION
 Depth Drilled 1,000 Feet Depth Cased 1,000 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 55 Feet
9 7/8 Inches 55 Feet 1,000 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>+ 1/2</u>	<u>1,000</u>

Perforations:
 Type perforation Torch
 Size perforation 4 1/2 x 10"
 From 940 feet to 1,000 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 1,000 feet

9. WATER LEVEL
 Static water level 6.65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality OK

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MITCHELL ENT. Contractor
 Address 4250 S. ARVILLE #262 Contractor
L.V. NEV. 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1617
 Signed Floyd Mitchell
 By driller performing actual drilling on site or contractor
 Date 10-15-96

Date started 9-11 1996
 Date completed 10-10 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>450 CFM</u> <u>250 PSI</u>	<u>35-40</u>	<u>1,000</u> <u>6</u>