


OFFICE USE ONLY
 Log No. 57864
 Permit No. _____
 Basin 16a



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14948

1. OWNER Tim Allison ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6140 Lisa Lane 6140 Lisa Lane
Pahrump, NV 89041

2. LOCATION NE 1/4 NE 1/4 Sec. 15 T 21S N/S R 53E E Nye County
 PERMIT NO. _____ 44-691-04 Mesa Oeste Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dark Brown Clay		0	18	18
Light Brown Clay		18	38	20
Light Grey Clay		38	59	21
Light Brown Clay		59	80	21
Brown Clay	x	80	101	21
Brown Clay	x	101	120	19
Brown Clay	x	120	138	18
Brown Clay	x	138	158	20
Brown Clay	x	158	179	21
Brown Clay	x	179	200	21

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	200

Perforations:
 Type perforation Torch
 Size perforation .25 x 6
 From 130 feet to 150 feet
 From 170 feet to 190 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 10/14/96, 19____
 Date completed 10/15/96, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>n/a</u>	<u>.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
 Signed Jim Strickland
 By driller performing actual drilling on-site or contractor
 Date 10.28.96