

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. **57917**
 Rec. **19**
 Well No. _____
 Permit No. _____
Do not fill in

Owner **Gordon H. Bishop** Driller **Effinger Drill & Pump Serv.**
 Address **Box 1762** City _____ Address **Box 539** Lic. No. **212**
 Location of well: **1/4 1/4 1/4** Sec. **5**, T**22** N/S, R**6** E, in **Clark** County
 or **Windswept Road**
 Water will be used for **Domestic** Total depth of well **235 feet**
 Size of drilled hole **12 inch** Weight of casing per linear foot _____
 Thickness of casing **3/16** Temp. of water _____
 Diameter and length of casing **10 3/4"OD 193 feet -- 8 5/8"OD 48 feet**
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure _____
 If nonflowing well give depth of standing water from surface **123 feet from top of casing .**
 If flowing well describe control works _____
(Type and size of valve, etc.)
 Date of commencement of well **January 6, 1959** Date of completion of well **January 21, 1959**
 Type of well rig **"Star 71"**

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	Red Sand & Gravel
3	4	1	Caliche
4	13	9	Sandy Clay & Gravel
13	28	15	Rock & Gravel
28	34	6	Limestone
34	41	7	Sand, Rock & Gravel
41	47	6	Limestone
47	63	16	Sand & Gravel
63	65	2	Limestone
65	77	12	Yellow Clay & Gravel
77	83	6	Red Sandy Clay & Gravel
83	106	23	Yellow Clay
106	109	3	Limestone
109	121	12	White Clay
121	126	5	Red Sandy Clay
126	131	5	Sand (Water)
131	156	25	Red Sand
156	190	34	Red Sand & Gravel (Water)
190	195	5	Red Clay
195	235	40	Red Sand & Gravel (Water)

Water-bearing Formation, Casing Perforations, Etc.
 Chief aquifer (water-bearing formation)
 from **195** to **235** ft.
 Other aquifers _____
 First water at **126** feet.
 Casing perforated
 from **193** to **235** ft.
 Size of perforations
1/8" x 15"



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	Remarks—Seals, Grouting, Etc.
10 3/4	0	193.	193	Cemented from 0 to 130 feet 3 yards of cement 48" 8 5/8"OD liner in well.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed..... Well Driller

By *A. J. Eyringer*

License No. *212*

Dated *January 21*, 19 *59*

(Not to be filled in by Driller)
