WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58159
Permit No. 62208
Basin 212

NOTICE OF INTENT NO. 15107

1. OWNER MH, inc.
MAILING ADDRESS 3 Shadow Creek Dr.
No. Las Vegas, NV 89031

ADDRESS AT WELL LOCATION
Shadow Creek Golf Course

2. LOCATION NW ¼ NW ¼ Sec. 36 T. 19S N/S R. 61 E. Clark County
PERMIT NO. 62208 T (Issued by Water Resources) 124-36-110-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red Clay, some		0	485	485
Gravel				
Blue-Green Clay		485	610	125
Brown Sandy Clay		610	776	166
Brown Clay		776	1067	291
Brown Sandy Clay		1067	1177	110
Brown Sandy Clay		1177	1344	167
with Sandy Stringers				

NOV 26 1996

Date started 8/9/, 1996
Date completed 9/16/, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	106'	24

8. WELL CONSTRUCTION
Depth Drilled 1344 Feet Depth Cased 1320 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
28	Inches	0	Feet	51	Feet
18 1/2	Inches	51	Feet	1344	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20 3/4			+2	51
10 3/4			51	140
10 3/4			440	620
10 3/4			720	1000
10 3/4			1300	1340

Perforations:
Type perforation Johnson Screen
Size perforation .060
From 140 feet to 440 feet
From 620 feet to 720 feet
From 1000 feet to 1300 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 1344 feet

9. WATER LEVEL
Static water level 74' 5" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling (Contractor)
Address 4185 W. Harmon (Contractor)
Las Veagas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 42864
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1851
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date November 22, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627